



SUB AND SUPERCRITICAL EXPERIENCE ON ESKOM COAL-FLEET

Centre for Science and
Environment Conference

Naushaad Haripersad – Eskom

17th March 2016



DISCLAIMER



This presentation does not constitute or form part of and should not be construed as, an offer to sell, or the solicitation or invitation of any offer to buy or subscribe for or underwrite or otherwise acquire, securities of Eskom Holdings SOC Limited (“Eskom”), any holding company or any of its subsidiaries in any jurisdiction or any other person, nor an inducement to enter into any investment activity. No part of this presentation, nor the fact of its distribution, should form the basis of, or be relied on in connection with, any contract or commitment or investment decision whatsoever. This presentation does not constitute a recommendation regarding any securities of Eskom or any other person.

Certain statements in this presentation regarding Eskom’s business operations may constitute “forward looking statements”. All statements other than statements of historical fact included in this presentation, including, without limitation, those regarding the financial position, business strategy, management plans and objectives for future operations of Eskom are forward looking statements.

Forward-looking statements are not intended to be a guarantee of future results, but instead constitute Eskom’s current expectations based on reasonable assumptions. Forecasted financial information is based on certain material assumptions. These assumptions include, but are not limited to continued normal levels of operating performance and electricity demand in the Customer Services, Distribution and Transmission divisions and operational performance in the Generation and Primary Energy divisions consistent with historical levels, and incremental capacity additions through the Group Capital division at investment levels and rates of return consistent with prior experience, as well as achievements of planned productivity improvements throughout the business activities.

Actual results could differ materially from those projected in any forward-looking statements due to risks, uncertainties and other factors. Eskom neither intends to nor assumes any obligation to update or revise any forward-looking statements, whether as a result of new information, future events or otherwise.

In preparation of this document certain publicly available data was used. While the sources used are generally regarded as reliable the content has not been verified. Eskom does not accept any responsibility for using any such information.

CONTENTS

- Eskom Overview
- Coal New Build Technology
- Technology Selection and Criteria
- Lessons Learnt


ESKOM AT A GLANCE




- Strategic 100% state-owned electricity utility, strongly supported by the government
- Supplies approximately 95% of South Africa's electricity
- Performed 201 788 household electrification connections during the year, the highest in a single year since 2002
- As at 31 March 2014:
 - 5.2 million customers (2013: 5.0 million)
 - Net maximum generating capacity of 42.0GW (2013: 41.9GW)
 - 17.4GW of new generation capacity being built, of which 6.1GW already commissioned
 - Approximately 359 337km of cables and power lines
 - 46 919 employees, inclusive of fixed-term contractors, in the group (2013: 47 295)
- Moody's and S&P stand-alone credit ratings: b1 and b- respectively with a negative outlook

Number of electrification connections


Number




Generation capacity – 30 September 2014



ESKOM'S PURPOSE, VALUES AND STRATEGIC OBJECTIVES



POWER STATION MAP



NEW COAL BUILD



In order to accelerate progress on the Medupi Power Station Project, additional shifts were introduced, 24 hours a day, seven days week. Unit 6 reached its full load of 794MW on 26 May 2015

ESKOM DESIGN UNIT EFFICIENCY BASED GROSS OUTPUT



POWER STATION	EFFICIENCY (%)
Arnot	37.7
Camden	33.3
Duhva	37.6
Grootvlei	32.2
Hendrina	34.5
Kendal	36.6
Komati	29.3
Kriel	36.8
Kusile*	41.9
Lethabo	38.7
Majuba	38.5
Matimba	36.4
Matla	37.6
Medupi*	41.4
Tutuka	36.4

*Based on Indicative average efficiencies across Plants / *Denotes Supercritical Plants*

TECHNOLOGY SELECTION PROCESS AND CRITERIA – SUB VS SUPERCRITICAL



The feasibility phase of the project considered both sub- and super-critical pulverized fuel technologies for implementation.

Through the technical and financial evaluation processes followed during the feasibility phase, it emerged that the **super-critical option** is the preferred technology solution.

The term “super-critical” refers to the critical transition point of water to steam at pressures over 22 mega Pascal (MPa). Super-critical units typically refer to main steam conditions of 24 to 30 MPa and 538 to 600 degrees Celsius (°C), with a single reheat stage at 566 to 600°C.

The super-critical boiler is a once through design which (with sliding pressure) means that heating, evaporating, and superheating of the incoming feed water are completed within a single pass through the evaporator tubes and therefore does not require the use of a steam drum to separate and re-circulate water during normal operation.

This technology provides improved cycle efficiency and hence improved environmental performance.

TECHNOLOGY SELECTION PROCESS AND CRITERIA – SUPERCRITICAL BENEFITS



The benefits of super-critical technology are:

- Increased gross efficiencies. This increase in efficiency results in a reduction in coal consumption of approximately 5%.
- A reduction in emissions in the order of 5%.
- Super-critical plant performance in terms of availability indicators is comparable to that of current Eskom plant performance according to a VGB report *"Availability of Thermal Power Plants"* for the operation period from 1995-2004.


TECHNICAL SPECIFICATIONS – MEDUPI AND KUSILE



Plant type	Super critical pressure with reheat
Boiler type	Once-through sliding pressure, tower type
Fuel	Hard coal (HHV 18.7 MJ/kg)
Plant output	6 x 800 MW _e (4,800 MW _e)
Turbine type	Single reheat condensing
Steam condition	241 bar/560 °C/570 °C
Condenser	Air-cooled condenser
Condenser pressure	141 mbar at 23.7 °C ambient
Generator	GIGATOP 2 poles, power factor = 0.9, 50 Hz

M.Koko/Y.Singh, Overview of the Eskom and South African New Build Programme, VGB PowerTech 1/2 2016.

MATERIAL DESIGN CONVECTIVE PATH: MEDUPI & KUSILE



Morris Moraga, Corporate Consultant, Eskom, Publication African Fusion, 2010

Lessons Learnt

USE OF INCORRECTLY APPROVED WELDING PROCEDURES



During post-production and in some cases during installation, it was discovered that certain welding procedures were incorrectly approved.

These procedures needed to be re-approved using actual production parameters. Of the over 200 procedures requiring re-approval, 4 procedures on thick-walled components affecting X10Cr-MoVNb9-1 and 10CrMo9-10 material did not pass.

This resulted in components already installed on Medupi Unit 6 and Kusile Unit 1 requiring in-situ repairs or additional post-weld heat treatment.

Components affected included P91 circular weld on headers, separator vessels (eventually all four replaced on Medupi Unit 6) and the start-up vessel.

POST-WELD HEAT TREATMENT CHARTS FRAUDULENTLY PRODUCED



Heat treatment charts were produced without heat treatment or incorrect heat treatment. Over 9,000 welds which were potentially affected had to be verified to establish whether post-weld heat treatment (PWHT) was performed.

This resulted in more than 400 welds with wall thickness ≤ 10 millimeters (mm) being cut out and replaced and more than 400 welds with wall thickness > 10 mm being heat-treated.

Areas cut and re-welded included the inlet and outlet connecting tubes of super heater 3 and re-heater 2.

DATABOOK APPROVALS



During the review of databooks for final approval, it was discovered that there were additional welding procedures not appropriately qualified thus requiring re-qualification.

Welder qualifications and re-testing documentation was missing and PWHT charts showed deviations from procedures.

A significant amount of work had to be done post-fabrication and installation to close out the databooks prior to pressure test.

SOUTH AFRICA – SUPERCRITICAL FUTURE?



Samcheok 4 x 550 MWe Supercritical CFB Boiler



Each Unit	English	Metric
Steam Capacity	550 MWe	1,600 MWth
Unit Steam Flow (SH/RH)	3,461 / 2,820 kpph	437 / 354 kg/s
Main Steam Pressure (SH/RH)	3,728 / 783 psi	257/53 bar (a)
Main Steam Temp.	1,117 / 1,117 °F	603 / 603 °C
Full Load Emissions	SOx < 50 mg/Nm ³	
	NOx < 50 mg/Nm ³	
Fuel : Coal	Moisture: 20-43%	
	Ash in dry fuel: 1.5-17.0%	
	Sulfur in dry fuel: 0.1-1.0%	
	Biomass co-firing	





Thank you

Naushaad Haripersad
Manager: Clean Coal Technologies
Research, Testing and Development
Eskom Holdings Limited SOC

Office : +27 11 629 5650
Mobile : +27 83 661 2332
Fax : +27 86 606 2332
E-mail : naushaad.haripersad@eskom.co.za